

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0026:165 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Models 4098-9781, 4098-9782, 4098-9783, 4098-9784, 4098-9785, 4098-9786 and 4098-9787 smoke detector bases with or without Model 4098-9804 or 4098-9822 relay module. Models 4098-9782 and 4098-9786 employ an integral audible device. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as smoke detector bases for use with Model 4098-9700 series detector heads and Model 4100 MAPNET II transponder (CSFM Listing No. 7165-0026:160 and 7170-0026:187) or Model 2120-7042 CDT transponder (CDT MAPNET II) (CSFM Listing No. 7170-0026:125 and 7165-0026:126) or Model 4020-8001 fire alarm control unit (CSFM Listing No. 7165-0026:178) or Model 4010 series fire alarm control unit (CSFM Listing No. 7170-0026:226).

*Rev. 05-12-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**